SUNSHUBH TECHNOVATIONS PVT LTD

#402, Hill view apartment, Adarshnagar 2nd Cr, HUBLI-580 029. Karnataka, INDIA Germany off: NeuerWeg 166, 47803 Krefeld, Dusseldorf.

| WATER | ENERGY | POLLUTION | ORGANIC |
|--------------|--------------|-----------|--------------|
| Harvesting | Efficiency | Minimize | Farming |
| Conservation | Conservation | Eliminate | Worm compost |
| Management | Generation | Manage | Benefits |



Regd: Certified Energy Auditors. GOI (EA 3485), Germany: Anbieter-Nr 1041388
www.sunshubhrenewables.com, Email: ceo@sunshubhrenewables.com, Ph: 94492 83505, 94490 33505

www.sunshubhrenewables.com, Email: ceo@sunshubhrenewables.com, Ph: 94492 83505, 94490 33505 CIN: U74999KA2020PTC136321, PAN:ABECS0250Q, TAN:BLRS77362F GST No: 29ABECS0250Q1ZX

GREEN ENERGY COMPUTATION CERTIFICATE

I, Mallikarjun A Kambalyal, certify that, the Energy Use data of KLE ACADEMY OF HIGHER EDUCATION AND RESEARCH, Belagavi has been verified and the Green Energy sourcing through Open access has been confirmed.

The inference is drawn based on the information and energy bills made available for evaluation for the operating period upto June 2024.

Clean Energy Computation for the academic year 2023-24.

| Details. | Energy in KWh | Source: | Percentage Share |
|---|------------------|-----------------------|---------------------|
| Total Energy sourced | 156,19,833 | HESCOM billing | - |
| Grid energy sourced | 12,57,833 | Grid souurse | 8.05 % |
| Open Access attributed to Solar & Wind Power generation agencies. | 135,42,000 | Open access records. | 86.70 % |
| Captive power plant - Rooftop Solar Energy not included in Grin sourcing | 8,20,000 | In house energy data. | 5.25 % |

Total geen energy sourced: 91.95 % (143,62,000 KWh)

This Certificate is issued based on the documents made available by the institute.

Hubli

Authorised Auditor.

Mallikarjun A. Kambalyal B.E (E&C)

Certified Energy Auditors EA-3485.

ISO 50001:2011 & ISO1400 1420 15 r Jurad Auditoriya Date: 9.11.2024

Certified Energy Auditor-EA 3485 ISO 50001:2011, ISO 14001:2015 LEAD AUDITOR